

ENGLISH

TO INSTALL:

WARNING: TO BE INSTALLED AND/OR USED IN ACCORDANCE WITH APPROPRIATE ELECTRICAL CODES AND REGULATIONS.

WARNING: IF YOU ARE NOT SURE ABOUT ANY PART OF THESE INSTRUCTIONS, CONSULT AN ELECTRICIAN.

CAUTION: OUTLET MUST BE WIRED TO A SEPARATE 3-WIRE CIRCUIT OF UP TO #4 AWG SIZE CONDUCTORS.

NOTE: This device may be used with copper, copper-clad, or aluminum wire.

1. **WARNING:** TO AVOID FIRE, SHOCK, OR DEATH; **TURN OFF POWER** AT CIRCUIT BREAKER OR FUSE AND TEST THAT the POWER IS OFF BEFORE WIRING!
 2. Remove insulation from wire per strip gage as shown on back of device, approximately 1/2 inch (1.3 cm).
 3. Determine appropriate terminal for each wire per **wiring diagram**.
 4. Insert wires into proper terminals (**refer to wiring diagram**). Tighten terminal screws to 25 in.-lbs. of torque. **CAUTION:** Terminal screws must tighten onto conductor only, not insulation.
 5. Mount device using long mounting screws. Attach wallplate (sold separately).
 6. Restore power to circuit breaker or fuse.
- Installation is complete.**