
正面

反面

Item:

HT-G2LHB-2FT4L-F81702/277-240D

LED HIGH BAY



SAFETY INSTRUCTION

M WARNING

• To reduce the risk of death, personal injury or property damage from fire, electric shock, falling parts, cuts/abrasions, and other hazards read all warnings and instructions

included with and on the fixture box and all fixture labels.

• Before installing, servicing, or performing routine maintenance upon this equipment, follow these general precautions.

• Commercial installation, service and maintenance of luminaires should be performed by a qualified licensed electrician.

• For the installation: If you are unsure about the installation or maintenance of the luminaires, consult a qualified licensed electrician and check your local electrical code.

• To prevent wiring damage or abrasion, do not expose wiring to edges of sheet metal or other sharp objects.

• Do not make or alter any open holes in an enclosure of wiring or electrical components during kit installation.

A WARNING

• Turn off electrical power at fuse or circuit breaker box before wiring fixture to the power

• Turn off the power when you perform any maintenance.

• Verify that supply voltage is correct by comparing it with the luminaire label information. • All wiring connections should be capped with UL approved wire connectors.

A CAUTION

• Avoid direct eye exposure to the light source while it is on.

• Account for small parts and destroy packing material, as these may be hazardous to children.

• Risk of burn. Disconnect power and allow fixture to cool before changing bulb or handing fixture.

NOTICE: Green ground screw provided in proper location. Do not relocate.

NOTICE: Minimum 90°C supply conductors.

NOTICE: Specifications and dimensions subject to change without notice.


NOTICE: Suitable for Dry or Damp location.

TOOLS REQUIRED





PACKAGE CONTENT






	PARTS	pcs
Α	vhook	2
В	chain	2
C	LED fixture	1

INSTALLATION INSTRUCTION


General Wiring Diagram

Black(Line)




Dimming wire to 0-10v IEC compliant control





INSTALLATION INSTRUCTION

Field-Adjustable CCT



The end users may adjust the color temperature by the DIP switch buttons integrated into the driver. The DIP switch is accommodated with 2 options (left and right), corresponding to 2 color temperatures, which can perform the desired color temperatures.

Factory Setting: 5000K

1. DIP switch is located onto the side of the fixture.

2. Select color temperature by sliding switch left or right to the desired value.

Installation Step:

Always turn off the power supply from main circuit breaker first! Chain Mounting with V hook

Step1:Clip the brackets to the slots of fixture

Step3:Attach provided chain to the V-hooks and mounting surface.

• Clean all residues/fingerprints from the new LED high bay and lens. Double check all hanging hardware before moving onto the next installation.

WARRANTY

This product is warranted for 5 years from the date of purchase.

Step2:Attach provided V-Hooks to brackets.

**NOTE: Purple and grey lead inside the driver compartment are 0-10V (low

voltage) dimming leads. Connect to dimming low voltage wiring only.